ADULT OR CHILD DAY CARE FOR LESS THAN 24 Hours 1,2  CODE SECTIONS and PAGE REFERENCES are from the 2018 North Carolina Building Code						
OCCUPANCY GROUP	<b>R-3</b> [ <b>§310.5</b> ; page 46]	<b>R-4</b> [ <b>§310.6</b> ; page 46]	I-4 <sup>4</sup> [§308.6; §308.6.1; §308.6.2; §308.6.3; §308.6.4, §308.6.5 page 45]	<b>E</b> <sup>3,8</sup> [ <b>§308.6.1</b> ; page 45]	E <sup>3,8</sup> [§305.2; §305.2.1 - §305.2.3 page 38] CHILDREN ONLY (ALSO INCLUDE Facilities Licensed by DHSR Mental Health Section)	A-3 (This Occupancy Group is not Licensed by Div of Aging or DHSR Mental Health Section) ADULTS ONLY
Age (in years)	Any	Any	Adults and Children 2 ½ or less	2 ½ or less	Older than 2 ½	Any
Occupant Load (in persons)	1 to 8 <sup>5</sup>	6 to 16 <sup>6</sup>	> 5	6 to 100	> 5	> 50
Portable Fire Extinguishers	2-A:10-B:C	2-A:10-B:C	§906 NC Fire Code	§906 NC Fire Code	§906 NC Fire Code	§906 NC Fire Code
Automatic Sprinklers	NR <sup>7</sup> §903.2.8 exc. 1	NR <sup>7</sup> §903.2.8 exc. 1	NR <sup>4</sup> §903.2.6 exc. 2	NR <sup>7</sup> <b>§903.2.3</b>	NR <sup>7</sup> <b>§903.2.3</b>	Required §903.2.1.3
Manual Fire Alarms	NR	Required	Required	Required	Required	Required when Occupant Load > 300
Floor Level:					1 <sup>st</sup> grade + younger: on LED	No Limitation
Not Sprinkled	On LED [ <b>§429.1.1</b> ; page 74]	Not addressed	On LED [ <b>§429.1.1</b> ]	On LED with exit door direct to exterior On LED [§429.1.2; pg 94]	2 <sup>nd</sup> grade: not more than 1 story above LED	
Sprinkled	On LED [§429.1.1]		On LED [ <b>§429.1.1</b> ]	NR	[ <b>§430.3</b> ; page 94]	
Number of Exits	[Table 1006.3.2.2(2), 1006.3.1 & Table 1006.2.1; §1006.2.1 Exception Number (1) table	2 except where on LED + direct exit to exterior [§429.1.2 + Exc.; Table 1006.3.2(2) Footnote e]	2 required where occupant load exceeds 10 [Table 1004.1.2, Table 1006.2.1 & Table 1006.3.2]	2 except where on LED + direct exit to exterior [§429.1.2 + Exc.; Table 1004.1.2]	2 except where on LED + direct exit to exterior [§429.1.2 + Exc.; Table 1004.1.2]	2 required where occupant load exceeds 49 [Table 1004.1.2 & Table 1006.3.2(2)]

- 1 Care Services providing services to any child for less than four (4) hours per day and/or less than four (4) months a year are not licensed or regulated by the Division of Child Development; however, NC Building Code requirements shall apply [§305.2]. PROGRAM TYPE EXAMPLE: Summer camps, Pre-School Care or After School Care.
- 2 Existing facilities do not have to meet the 2018 NC Building Code unless doing major renovations, expanding or moving to a different facility or site. You can use the 2018 North Carolina Existing Building Code for all day cares facilities going into existing building. There is no difference on whether it is a new license or transfer license (change in ownership). Please see governing licensing agencies for Building Inspection Forms.
- 3 Assembly spaces (i.e., auditorium, cafeteria, gymnasium, library, etc.) which are accessory to Group E buildings are not considered as separate occupancies.) [Section 508.2]
- 4 I-4 Day Care Facilities on the LED occupant load great than 5 with no direct exterior exits for classrooms containing children Pre-School Age (PSA) or provide care for more than 100 children (PSA)
- 5 Allowed to have five (5) preschool children and three (3) school-aged (K-12) children [Div. Of Child Development Licensing Rules and Section 310.5 on page 46]

controls]

- 6 Allowed to have no more than twelve (12) children when any preschool child is in child care. This number may increase to fifteen (15) if all children are school-aged (K-12). [Div. Of Child Development Licensing Rules]
- 7 Table 1020.1 Footnote d: Facilities without sprinkler systems shall have 1-hour fire-resistant corridors regardless of occupant loads. Group E is Table 1020.1 Footnote g
- Public buildings currently approved for Education Occupancy should be considered approved for the licensed operation of a child care center within its facilities when the participants in care are school age. Session Law 2009-123: General Statutes Chapter 115C Section 1 §115C-521.1 Building Standards for Preschool Students