

**CHAPTER XX  
STORAGE OF REFRIGERANTS**

**2001—GENERAL**

All refrigerants in excess of the amounts within an approved refrigeration system shall be stored in a machinery room in their original approved containers, and shall not exceed the amount contained in the system; in no event shall the storage exceed 300 pounds.

EXCEPTION: The provisions of this Section shall not apply to any refrigerant in any scientific laboratory during tests and experiments nor to refrigerant in the actual process of manufacture.

Whenever refrigerant is removed or withdrawn from any refrigerating system it shall be discharged into an approved shipping container.

No portable refrigerant container shall be connected to any refrigerating system for a period of longer than is necessary to charge or discharge such refrigerating system.

