



APPENDIX C
CODE CHANGE PROPOSAL
NORTH CAROLINA
BUILDING CODE COUNCIL

B-2

1429 Rock Quarry Road, Suite 105
Raleigh, North Carolina 27610
(919) 647-0008
david.rittlinger@ncdoi.gov

Petition for Rule Making

Item Number _____

Granted by BCC _____
Denied by BCC _____

Adopted by BCC _____
Disapproved by BCC _____

Approved by RRC _____
Objection by RRC _____

PROPONENT: Adam S _____ PHONE:(910)795-5610
REPRESENTING: Carolina's Association of RV Parks and Campgrounds _____
ADDRESS: 2333 White Lake Drive _____
CITY: Elizabethtown _____ STATE: NC _____ ZIP: 28337 _____
E-MAIL: Adam@Campclearwater.com _____ FAX: () - _____

North Carolina State Building Code, Volume: 2023 NC Electrical Code- Section 210.8 Ground-Fault Circuit-Interrupter Protection for Personnel, (F) Outdoor Outlets

CHECK ONE: [X] Revise section to read as follows: [] Delete section and substitute the following:
[] Add new section to read as follows: [] Delete section without substitution:

~~LINE THROUGH MATERIAL TO BE DELETED~~

UNDERLINE MATERIAL TO BE ADDED

Please type. Continue proposal or reason on plain paper attached to this form. See reverse side for instructions.

Please see attached document, Below this page.

Will this proposal change the cost of construction? Decrease [] Increase [] No [X]
Will this proposal increase to the cost of a dwelling by \$80 or more? Yes [] No [X]
Will this proposal affect the Local or State funds? Local [] State [] No [X]
Will this proposal cause a substantial economic impact (≥\$1,000,000)? Yes [] No [X]

- Non-Substantial – Provide an economic analysis including benefit/cost estimates.
- Substantial – The economic analysis must also include 2-alternatives, time value of money and risk analysis.
- Pursuant to §143-138(a1)(2) a cost-benefit analysis is required for all proposed amendments to the NC Energy Conservation Code. The Building Code Council shall also require same for the NC Residential Code, Chapter 11.

REASON:

For interpretation clarification, NFPA 70 551.71 defines the safe standard for electrical supply on a RV park Pedestal.

Signature: Adam Smith_____

Date: 1-31-2024_____

FORM 11/26/19

(F) Outdoor Outlets.

For dwellings, all outdoor outlets, other than those covered in [210.8\(A\)](#), Exception No. 1, including outlets installed in the following locations, and supplied by single-phase branch circuits rated 150 volts or less to ground, 50 amperes or less, shall be provided with GFCI protection:

- (1)Garages that have floors located at or below grade level
- (2)Accessory buildings
- (3)Boathouses

If equipment supplied by an outlet covered under the requirements of this section is replaced, the outlet shall be supplied with GFCI protection.

Exception No. 1:

GFCI protection shall not be required on lighting outlets other than those covered in [210.8\(C\)](#).

Exception No. 2:

GFCI protection shall not be required for listed HVAC equipment. This exception shall expire September 1, 2026.

Exception No. 3:

GFCI protection for an RV park pedestal is covered in 551.71(F)

INSTRUCTIONS

Each proposed Code change request shall comply with the following policies:

Rule 1: The Original and twenty-two (22) copies of the proposed Petition for Rule-Making along with supporting documentation shall be filed with the Building Code Council Secretary. Submit one (1) electronic copy via email.

Rule 2: The filing shall be received by the first day of the month prior to the quarterly scheduled meeting date. Example: A December meeting date will require filing by November 1 prior to the meeting.

Rule 3: Each request shall be typewritten on this form and shall contain the following:

- (1) The proposed rule change must be set forth in full and contain explicit reference to the affected section or sections of the Code.
- (2) The request shall state the reasons for the proposed rule change with supporting documentation.
- (3) The proposed rule change shall comply with the standards set forth in GS 143-138(c) and reference to the particular standards shall be set forth in the request for the amendment.
- (4) The proposed rule change shall contain an economic impact analysis as required by GS 143-138(a).
- (5) A proposed rule change to the NC Energy Conservation Code shall have an accompanying cost-benefit analysis as required by GS 143-138(a1)(2).

Rule 4: When a request is improperly filed or not in accordance with all the rules listed above, the BCC Secretary shall reject the submittal and notify the applicant of the proper procedure to follow.

Rule 5: Upon the proper filing of a request, the BCC Secretary shall forward one copy of said request to each council member prior to the scheduled meeting date. Persons filing proposed petitions are hereby notified of the place and time of the scheduled hearings. The BCC Secretary shall cause to be published the notice of public hearing as specified in GS 143-138(a).

Rule 6: The Council shall either Grant or Deny the proposed Petition for Rulemaking at the meeting following receipt of the proposed rule change. The Council will take no further action on items that are Denied. Granted items may be referred to Committee for review.

Rule 7: The Council will hold a public hearing on Granted items at the next quarterly scheduled meeting. The Council will take final action on Granted items at the next quarterly scheduled meeting after the public hearing.

Timeline Example

Petition received:	February 1
Petition Granted:	March BCC meeting
Notice of Hearing published:	April NC Register
Committee review:	May - June
Hearing held:	June BCC meeting
Final Adoption:	September BCC meeting
Rules Review Meeting:	November RRC meeting
Approved:	December 1