

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Application of the 6 Foot Height Limit for Item #11 of Section 603.1

Code: 2018 Building Code
Section: 603.1, Item #11

Date: September 6, 2018

Question:

Does the 6 foot height limit noted in Item #11 refer to just the “wood panels or similar light construction”?

Answer:

Yes, the 6 foot height limit noted in Item #11 of section 603.1 does refer to just the phrase “wood panels or similar light construction”. The fire-retardant-treated wood and 1-hour fire-resistant-rated construction mentioned in Item #11 are not limited to 6 feet.

Keywords:

FRTW, Type I, Type 1, Type II, Type 2, noncombustible, combustible, partition, partial partition, partial wall