

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**In-Use Type Receptacle Covers in Wet Locations**

**Code:** 2014 Electrical Code

**Date:** March 16, 2017

**Section:** 406.9(B)

**Question:**

Are in-use type receptacle covers (bubble covers) required for all receptacles in wet locations?

**Answer:**

All 15 and 20 ampere, 125- and 250- volt receptacles installed outdoors in wet locations are required to have an enclosure that is weatherproof whether or not the attachment plug cap is inserted.