

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Alarm Audibility

Code: 2012 Fire Prevention Code
Section: 907.6.2.1

Date: September 1, 2011

Question:

Do the private mode alarm audibility levels identified in NFPA 72 supercede the audibility levels identified in Section 907.6.2.1?

Answer:

No. When the code conflicts with a referenced standard, the code is used in accordance with Section 102.6 of the North Carolina Fire Prevention Code.

It should be noted that the exception to Section 907.6.2.1 allows the audible notification devices to be replaced with visible notification devices in Group I-2 (hospital) critical care areas.