

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

High-Piled Combustible Storage Area

Code: 2012 Fire Prevention Code

Date: September 1, 2011

Section: Table 2306.2

Question:

Is the size of the "high-piled storage area" the area used for the racks or the overall size of the room?

Answer:

The answer, defined in Section 2302, is the area designated, intended, proposed or actually used for high-piled storage.

It should be noted that there are conditions such as movable racks or engineering analysis in accordance with Section 2304.2 that require the size of the room to be considered for Table 2306.2.