

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

High-Piled Combustible Storage Area

Code: 2018 Fire Prevention Code
Section: Table 3206.2

Date: January 1, 2019

Question:

Is the size of the "high-piled storage area" the area used for the racks or the overall size of the room?

Answer:

The answer, defined in Section 202, is the area designated, intended, proposed or actually used for high-piled storage.

It should be noted that there are conditions such as movable racks or engineering analysis in accordance with Section 3204.2 that require the size of the room to be considered for Table 3206.2.