

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Cast Iron Fittings for Steel or Wrought-iron Gas Piping

Code: 2012 Fuel Gas Code

Date: September 1, 2011

Section: 403.10.4

Question:

Can cast iron fittings be used for steel or wrought-iron gas piping?

Answer:

Yes. Item #2 of Section 403.10.4 allows the use of cast iron fittings for steel or wrought-iron gas piping. The cast iron fitting must also meet the requirements of Item #5 of Section 403.10.4.