

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Bathroom Exhaust Duct Material for Dwellings and Townhouses

Code: 2012 Mechanical Code

Date: September 1, 2011

Sections: 603.4, 603.5, 501.4, and 502.18

Question:

For one and two family dwellings and townhouses, what are the duct material requirements for bathroom exhaust?

Answer:

For one and two family dwellings and townhouses, duct materials for bathroom exhaust must comply with the requirements of Chapter 6 of the NC Mechanical Code. Section 603.4 or 603.5 requires metallic duct or UL 181 nonmetallic duct.