

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Toilet Facilities For Vegetable And Fruit Stands

Code: 2012 Plumbing Code

Date: September 1, 2011

Section: 403.1

Question:

Are toilet facilities required for vegetable/fruit stands?

Answer:

No, if the vegetable/fruit stand is located on the same parcel of land as the operator's dwelling and has no entrance into the stand for the customers, then toilet facilities are not required.

Yes, if the vegetable/fruit stand allows customers to enter the building, then toilet facilities are required (see table 403.1 mercantile for required toilet facilities).