

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Outdoor Fireplaces

Code: 2012 Residential Code
Section: R101.2.2

Date: July 1, 2012
Rev.: February 17, 2017

Question:

Does the Residential Code apply to standalone outdoor fireplaces?

Answer:

Maybe. The 2014-2016 Approved Cumulative Amendments (Effective 1/1/2016) addresses the definition of Accessory Structures and their Code requirements from section R101.2.2. Fireplaces located less than 10 feet from other buildings or lot lines would be required to meet the provisions of the code.

Reference:

R101.2.2 Accessory Structures. Accessory structures shall meet the provisions of this code. Accessory structures not listed below are not required to meet the provisions of this code.

1. Decks, See Appendix M,
2. Gazebos,
3. Retaining wall, See Section R404.4,
4. Detached masonry chimneys located less than 10 feet from other buildings or lot lines,
5. Swimming pools and spas, See Appendix G,
6. Detached carports,
7. *Docks, piers, bulkheads,* and waterways structures, See Section R324.

Exception: Portable lightweight aluminum or canvas type carports not exceeding 400 sq ft or 12' mean roof height and tree houses supported solely by a tree are exempt from the provisions of this code.

Key Words: BBQ, cooking, fireplace