

INFORMAL CODE INTERPRETATION

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Use of DASMA Technical Data Sheet 155h for Determining DP Ratings for Garage Doors

Code: 2012 Residential Code

Date: July 1, 2012

Section: Table R301.2(4)
Table 4502(b)

Question:

Can DASMA Technical Data Sheet 155h be used for determining alternate design pressures for garage doors?

Answer:

Yes. DASMA Technical Data Sheet 155h was inadvertently removed from footnote “a” of Table R301.2(4) and footnote “b” of Table 4502(b).

Keywords:

wind pressures, lateral loads