

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Glazing Labeling in Hazardous Locations

Code: 2018 NC Residential Code

Date: March 22, 2019

Section: R308.1

Question:

Is Section R308.1 referring to the glazing or the label being destroyed when removed?

Answer:

It is referring to the label itself and not the glazing. According to the 2015 IRC commentary, “A manufacturer can identify safety glazing with a removable paper designation, provided removal would destroy the designation. This ensures that the designation will not be applied to a noncomplying piece of glass”.

Keywords:

Tempered glass, spandrel glass