

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-661-5880**

Glazing Labeling in Hazardous Locations

Code: 2012 NC Residential Code

Date: February 8, 2016

Section: R308.1 Identification

Question:

Is the above referenced section referring to the glazing or the label being destroyed when removed?

Answer:

The label itself. According to the 2009 IRC commentary, "A manufacturer can identify safety glazing with a removable paper designation, provided it is destroyed during removal. This ensures that the designation will not be applied to a noncomplying piece of glass".

Keywords:

Tempered glass, spandrel glass