

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Double Door Exits

Code: 2018 Residential Code
Section: R311.2

Date: March 21, 2019

Question:

Are double doors permitted for the required exit if they have a total door opening equal to 36 inches?

Answer:

Yes. These doors are typically two 30-inch doors or two 32 inch doors. They can not have a stationary center mullion, but one leaf can have a toe and/or head bolt. The other leaf must be readily openable from the egress side without the use of a key or special knowledge or effort.

Key Words:

French, locks, latches, exterior