

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Projections on Stairway Walls

Code: 2018 Residential Code
Section: R311.7.1


Date: April 9, 2019

Question:

In one- and two-family dwellings may items other than railings, which are specifically addressed in R311.7 .1, be mounted on stairway walls and ceilings?

Answer:

Yes, with limitations. Elements such as trim, stringers or other items may be on the wall below the handrail or handrails as long as they do not exceed projection limits allowed for handrails. These items must not reduce the required clear stairway dimension allowed for handrails. Similarly, elements may project into the stairway above the 6 feet 8 inches requirement of Section R311.7.2. See 2015 IRC commentary Figure R311.7.1 attached below. The allowed projection areas are shaded.



Keywords:

Lights, sconce, shelves