

**NC Department of Insurance
Office of the State Fire Marshal - Engineering Division
1202 Mail Service Center, Raleigh, NC 27699-1202
919-647-0000**

Notching Deck Rail Posts

Code: 2018 NC Residential Code
Section: AM111

Date: March 20, 2019

Question:

Can the 4"x4" guard rail post as illustrated in figure AM111 be a notched section at its connection to the band joist and girders?

Answer:

No. Notching the rail post would reduce the section of the post that resist the required loads from Table R301.5. Notching of this post would require an engineer's analysis to determine if the remaining wood section can resist the loads from Table R301.5.

Keywords:

Handrail, support, cutting